



April 17, 2024

Dear Parents and Guardians,

We are writing to let you know that NFI North Contoocook School recently completed testing for lead in drinking water. This is part of an ongoing effort related to New Hampshire’s House Bill 1421, which requires school and child care facilities to test for lead in drinking water and to act when lead is found at levels at or above 5 parts per billion (ppb).

Lead is a toxic heavy metal that has a range of adverse health effects if inhaled or swallowed. Lead rarely occurs naturally in New Hampshire’s drinking water sources (groundwater or surface water) and typically enters drinking water due to the wearing away of piping, faucets, fixtures and other plumbing materials.

Because lead is tasteless, odorless and colorless in drinking water, testing is the only way to learn whether lead is present. It is important to sample each faucet or water fountain that is used for drinking or food prep because test results can vary between locations.

During recent testing, we collected samples from 4 drinking water outlets (e.g., bathroom faucets, classroom faucets, kitchen sinks), with 1 sample testing at or above 5 ppb, the level where action must be taken.

We have removed access to these outlets until the problem can be corrected. The table below shows a list of all of the tested outlets, their locations, sample results and our planned remediation.

Students are provided with drinking water in the form of bottled spring water from coolers.

Outlet Number	Location	Sample Result (ppb)	Planned Remediation
28040-01	Kitchen	1.5	
28040-02	Staff Bathroom	4.2	
28040-03	Student Bathroom 14	5.1	Posting for no drinking/handwashing only
28040-04	Student Bathroom 15	4.3	

All sample results and additional resources from the New Hampshire Department of Environmental Services (NHDES) can be viewed at [gettheleadoutnh.org](http://gettheleadoutnh.org). Please feel free to reach out with any questions.

Sincerely,

Heidi Foisy  
Program Director  
NFI North Contoocook School